


 Delhi Jal Board	DELHI JAL BOARD (GOVT. OF N.C.T. DELHI) QUALITY CONTROL LABORATORY, TRANS YAMUNA REGION TAHIRPUR DELHI-110093	ACWA-TYR
		Diary No. 1235 dt. 07.12.24
 Licence No- CRO/QM/L-8004274 as per IS/ISO 9001:2015	 एक कदम स्वच्छता की ओर	

NO: DJB/ACWA(TYR)/2024.....

DATE:- 07-12-2024

Analysis report of DJB water Supply samples collected from (1) Inlet (Water Tanker- DL-1M8644), (2) Outlet(Drinking water tap) of M/S FAIR CHILD PUBLIC SCHOOL, B-3/365, 33 FT. ROAD, HARSH VIHAR MANDOLI, DELHI-110093 for drinking purpose.

Ref. No. FCPS/MISC./2024/101, dated: - 02.12.2024

Challan No: - 208, dated: - 04.12.2024

Date of collection : 05-12-2024

S. No.	PARTICULARS	BIS:10500-2012 LIMITS		UNITS	RESULT	
		Desirable	Permissible		(1)	(2)
A.	Physical Examination					
1.	Colour	...	...	-	Clear	Clear
2.	Odour	...	...	-	Chlor.	Chlor.
3.	Turbidity	1.0	5.0	NTU	2.45	1.82
4.	pH Value	6.5-8.5	--	-	7.5	7.5
5.	Electrical Conductivity	--	--	µs/cm	261	258
6.	Total Dissolved Solids	500	2000	mg/l	170	168
B.	Chemical Examination					
7.	P th Alkalinity	...	...	mg/l	NIL	NIL
8.	Total Alkalinity	200	600	mg/l	82	80
9.	Total Hardness	200	600	mg/l	106	106
10.	Calcium as (Ca)	75	200	mg/l	27.2	28.0
11.	Magnesium as (Mg)	30	100	mg/l	9.12	8.64
12.	Ammonical Nitrogen	0.5	NR	mg/l	N.D	N.D
13.	Nitrite			mg/l	N.D	N.D
14.	Nitrate	45	NR	mg/l	1.89	1.91
15.	Sulphate	200	400	mg/l	32.18	33.15
16.	Chloride	250	1000	mg/l	16	14
17.	Fluoride	1.0	1.5	mg/l	0.08	0.06
18.	Total Iron	1.0	NR	mg/l	0.06	0.07
19.	Cyanide	0.05	NR	mg/l	N.D	N.D
20.	Residual Chlorine	0.2	1.0	mg/l	1.00	0.80
C.	Bacteriological Examination					
21.	Coliform count	Absent	NR	MPN/100ml	0	0

This Report
Pertains To
The Particular
Sample Only

REMARKS:- On the basis of above tested parameters, the water sample is found to be fit for drinking purposes.

REMARKS:- On the basis of above tested parameters, both water samples conform BIS: 10500-2012 and can be considered fit for drinking purpose.

(B.K Verma)
ACWA(TYR)
Asst. Chief Water Analyst
D.J.B. Govt. of N.C.T. of Delhi
Quality Control Zonal Laboratory (Tvr.)
Tahir Pur Dilshad Garden, Delhi

(A.G Susmitha)
BACTERIOLOGIST

(Gulesh Jainar)
CHEMIST

(Mayank Yadav)
A/CHEMIST